



SFL = STRUCTURAL FLOOR LEVEL

1 DRAINAGE PLAN
1 : 192

ISSUED FOR CONSTRUCTION

KEYNOTE LEGEND

GENERAL NOTES

- A VERIFY ALL DIMENSIONS ON SITE AND NOTIFY ARCHITECT/ENGINEER OF ANY DISCREPANCIES
- B NOTIFY ARCHITECT OF ANY DISCREPANCIES DUE TO UNFORESEEN CONDITIONS
- C IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO ASCERTAIN ALL SITE CONDITIONS PRIOR TO SUBMITTING THEIR BIDS
- G INSTALL ALL ITEMS IN ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS, SPECIFICATIONS AND STANDARDS
- h ALL CONCRETE TO BE MINIMUM C 30/37
- J ALL REBAR TO BE MIN. 66,000 PSI YIELD STRENGTH
- J ALL STRUCTURAL STEELWORK TO BE TO ASTM A 992
- K ALL PURLINS TO BE GALVANIZED COLD FORMED STEEL TO ASTM A 53