



## Request for Proposal

### Fire Alarm System – Design, Supply & Installation

#### 1. Introduction

Guyana Shore Base Inc. (GYSBI) invites qualified companies to submit proposals for the design, supply, and installation of a fire alarm system for various warehouses located at its Houston and McDoom facilities.

#### 2. Scope of Work

The selected contractor shall provide a complete fire detection system, including but not limited to:

- Addressable fire alarm panels (Honeywell or Fire-Lite)
- Communicator/transmitter for Honeywell CLSS system integration
- Back-up battery and surge protection for panels
- All required initiating devices, notification appliances, and associated components
- Installation materials and equipment
- Complete installation and labor
- Testing and commissioning
- Training for designated personnel

Bidders must submit proposals detailing:

- Experience in fire alarm system design and installation (including compliance with NFPA 72 and Guyanese fire standards)
- Design approach and methodology
- Pricing for design services, key system components (inclusive but not limited to panels, transmitters, detectors, and strobes) and installation (materials and labour)
- Proposed timelines for design and installation.

Only one bidder will be selected based on experience, technical expertise, and pricing structure.



## Stage 2: System Design & Pricing Confirmation

- The selected bidder will develop a detailed fire alarm system design for approval.
- Once approved, the final system cost will be calculated based on the pre-submitted pricing.
- Installation will proceed upon contract finalization.

### 3. Technical Requirements

- The fire alarm system must be addressable and integrated with existing systems.
- Components must include smoke/heat detectors, pull stations, strobes, horns, and backup power.
- All work must comply with NFPA 72 and Guyanese fire standards.

**Warehouses:** The fire detection system shall be installed in the following warehouses with the respective area dimensions:

- **GSB013:** 67m x 30m
- **GIE007:** 79m x 43m
- **GIE005:** 274m x 30m
- **GSB003:** 73m x 18m
- **GSB006:** 23.5m x 13m

### 4. Specific Submission Requirements

Bidders must provide:

- Company profile and experience in fire alarm installations.
- Detailed design methodology and project approach.
- Pricing for system components and labour.

### 5. SUBMISSION DETAILS

- Date published: April 10, 2025
- Deadline for Submission: May 8, 2025
- Submission Format: Single PDF document
- Submission Email Address: tenders@gysbi.com
- Clarifications & Queries: All inquiries can be submitted to the email address above.



## 6. DISCLAIMER

This RFQ does not constitute an offer to contract. Guyana Shore Base Inc. reserves the right to accept or reject any submission at its sole discretion and to proceed with the procurement in any manner it deems fit.

**Issued by:**

**GUYANA SHORE BASE INC. (GYSBI)**

**April 10, 2025**